

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/02/2012  
FORM APPROVED  
OMB NO. 0938-0391

|   |   |  |   |  |
|---|---|--|---|--|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION                      |   | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:<br><br>345259 | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING _____<br>B. WING _____  | (X3) DATE SURVEY COMPLETED<br><br>04/04/2012 |
| NAME OF PROVIDER OR SUPPLIER<br><br>SAMPSON REGIONAL MEDICAL CTR      |   |  | STREET ADDRESS, CITY, STATE, ZIP CODE<br>607 BEAMAN ST BOX 258<br>CLINTON, NC 28328                             |  |
| (X4) ID PREFIX TAG  | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)  | ID PREFIX TAG  | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETION DATE                         |
| F 000   | INITIAL COMMENTS<br><br>This facility is in compliance with the requirements of 42CFR Part 483, Subpart B, for Long Term Care Facilities (General Health Survey). | F 000  |   |  |
| LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE |   |  | TITLE   | (X6) DATE                                    |

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/30/2012  
FORM APPROVED  
OMB NO. 0938-0391

RECEIVED  
MAY 15 2012

|  |  |   |  |
|--|--|---|--|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:<br><br>345259 | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING 01 - MAIN BUILDING<br>B. WING | (X3) DATE SURVEY COMPLETED<br><br>04/26/2012 |
|--|--|---|--|

CONSTRUCTION SECTION

|  |   |
|--|---|
| NAME OF PROVIDER OR SUPPLIER<br><br>SAMPSON REGIONAL MEDICAL CTR | STREET ADDRESS, CITY, STATE, ZIP CODE<br>807 BEAMAN ST BOX 258<br>CLINTON, NC 28328 |
|--|---|

| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)  | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)   | (X5) COMPLETION DATE  |
|--------------------|---|---------------|---|---|
| K 051<br>SS=D      | <p>NFPA 101 LIFE SAFETY CODE STANDARD</p> <p>A fire alarm system with approved components, devices or equipment is installed according to NFPA 72, National Fire Alarm Code, to provide effective warning of fire in any part of the building. Activation of the complete fire alarm system is by manual fire alarm initiation, automatic detection or extinguishing system operation. Pull stations in patient sleeping areas may be omitted provided that manual pull stations are within 200 feet of nurse's stations. Pull stations are located in the path of egress. Electronic or written records of tests are available. A reliable second source of power is provided. Fire alarm systems are maintained in accordance with NFPA 72 and records of maintenance are kept readily available. There is remote annunciation of the fire alarm system to an approved central station. 19.3.4, 9.6</p> <p>This STANDARD is not met as evidenced by:<br/>A. Based on observation on 04/26/2012 the fire alarm panel was not tested due to the fact that the AC Power could not be disconnected.<br/>42 CFR 483.70 (a)</p> | K 051         | <ul style="list-style-type: none"> <li>The power supply breaker was identified and label was placed on the Fire Alarm panel.</li> <li>This is the only Fire Alarm panel and it has emergency power and battery back-up power.</li> <li>The system was tested on 4/27/12 with the power off of the panel as well as the power off of the battery charger. The Fire Alarm system activated throughout the building.</li> <li>The Fire Alarm Company, Johnson Controls will add this test to the annual fire alarm system testing.</li> <li>We will monitor to ensure this deficient practice does not recur by the annual testing and report it through the Sampson Regional Medical Center Fire and Safety Committee.</li> </ul> | <p>4/26/12</p> <p>4/27/12</p> <p>Annually</p> <p>Annually</p> |

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE: Thomas K. Heath TITLE: Director of Facility Operations (X6) DATE: 5/1/12

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

CD