

1 10A NCAC 14E .0210 is proposed for adoption under emergency procedures as follows:

2

3 **10A NCAC 14E .0210 CORRIDORS**

4 The width of corridors shall be sufficient to allow for patient evacuation by stretcher, but in no case shall patient-use
5 corridors be less than 60 inches.

6

7 History Note: Authority S.L. 2023-14, s. 2.4:

8 Emergency Adoption Eff.