

10A NCAC 14E .0211 DOORS

Minimum width of doors to all rooms needing access for stretchers shall be three feet. No door shall swing into corridors in a manner that might obstruct traffic flow or reduce the required corridor width except doors to spaces such as small closets not subject to occupancy.

*History Note: Authority S.L. 2023-14, s. 2.4;
Emergency Adoption Eff. July 18, 2023.*