

1 10A NCAC 14E .0211 is proposed for adoption under emergency procedures as follows:

2

3 **10A NCAC 14E .0211 DOORS**

4 Minimum width of doors to all rooms needing access for stretchers shall be three feet. No door shall swing into
5 corridors in a manner that might obstruct traffic flow or reduce the required corridor width except doors to spaces such
6 as small closets not subject to occupancy.

7

8 History Note: Authority S.L. 2023-14, s. 2.4;

9 Emergency Adoption Eff.