

STATEMENT OF ISOLATED DEFICIENCIES WHICH CAUSE NO HARM WITH ONLY A POTENTIAL FOR MINIMAL HARM FOR SNFs AND NFs	PROVIDER #  <b>345419</b>	MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	DATE SURVEY COMPLETE: <b>4/18/2013</b>
NAME OF PROVIDER OR SUPPLIER  <b>LEXINGTON HEALTH CARE CENTER</b>		STREET ADDRESS, CITY, STATE, ZIP CODE <b>17 CORNELIA DRIVE LEXINGTON, NC</b>	
ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES		
<b>F 278</b>	<p><b>483.20(g) - (j) ASSESSMENT ACCURACY/COORDINATION/CERTIFIED</b></p> <p>The assessment must accurately reflect the residents status.</p> <p>A registered nurse must conduct or coordinate each assessment with the appropriate participation of health professionals.</p> <p>A registered nurse must sign and certify that the assessment is completed</p> <p>Each individual who completes a portion of the assessment must sign and certify the accuracy of that portion of the assessment.</p> <p>Under Medicare and Medicaid, an individual who willfully and knowingly certifies a material and false statement in a resident assessment is subject to a civil money penalty of not more than \$1,000 for each assessment; or an individual who willfully and knowingly causes another individual to certify a material and false statement in a resident assessment is subject to a civil money penalty of not more than \$5,000 for each assessment.</p> <p>Clinical disagreement does not constitute a material and false statement</p> <p>This REQUIREMENT is not met as evidenced by: Based on observation, staff interview, and record review, the facility failed to accurately assess 1 of 26 residents (Resident #118) reviewed for assessments.</p> <p>Findings included:</p> <p>Resident #118 was admitted on 3/08/13. The resident's documented diagnoses included dysphagia, reflux, and chronic obstructive pulmonary disease.</p> <p>A review of the resident's medication orders started on 3/8/13 revealed Oxygen 2 liters per minute continuous oxygen therapy and 3 medications that were given by mixing oxygen with a liquid and the resident inhaling the vapor.</p> <p>The admission Minimum Data Set (MDS) with an Assessment Reference Date of 3/15/13 indicated no swallowing disorders, and no respiratory treatments including oxygen therapy</p> <p>The resident's nutritional diagnosis indicated poor eating related to dysphagia</p> <p>Interviewed the MDS Coordinator at 1:25 pm on 4/18/13 regarding the resident's inaccurate care plan. He did not give an indication as to why the assessment was inaccurate</p>		

Any deficiency statement ending with an asterisk(\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of

The above isolated deficiencies pose no actual harm to the residents

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/02/2013  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  345419	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____  B. WING _____		(X3) DATE SURVEY COMPLETED  C 04/18/2013
NAME OF PROVIDER OR SUPPLIER  LEXINGTON HEALTH CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 17 CORNELIA DRIVE LEXINGTON, NC 27292		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
F 000	INITIAL COMMENTS  There were no deficiencies cited as a result of the complaint investigation survey of 4/18/13. Event ID# 41SS11.	F 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.


DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  345419	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01  B. WING _____	(X3) DATE SURVEY COMPLETED  05/15/2013
NAME OF PROVIDER OR SUPPLIER  LEXINGTON HEALTH CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 17 CORNELIA DRIVE LEXINGTON, NC 27292	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	INITIAL COMMENTS  Surveyor: 27871 This Life Safety Code(LSC) survey was conducted as per The Code of Federal Register at 42 CFR 483.70(a); using the 2000 Existing Health Care section of the LSC and its referenced publications. This building is Type III (211) construction, one story, with a complete automatic sprinkler system. Facility is using special locking system per North Carolina State Building Code.	K 000		
K 012 SS=E	The deficiencies determined during the survey are as follows: NFPA 101 LIFE SAFETY CODE STANDARD  Building construction type and height meets one of the following. 19.1.6.2, 19.1.6.3, 19.1.6.4, 19.3.5.1	K 012	K 012 Door Closure has been adjusted on May 16, 2013. It now closes and latches properly. Maintenance staff will monitor as part of the monthly inspection process to ensure that door is latching appropriately.	
K 029 SS=E	This STANDARD is not met as evidenced by: Surveyor: 27871 Based on observations and staff interview at approximately 8:30 am onward, the following items were noncompliant, specific findings include: rated door in smoke wall( attic access is in maintenance shop) did not close and latch, to maintain the rating of wall to be smoke resistance.  42 CFR 483.70(a) NFPA 101 LIFE SAFETY CODE STANDARD  One hour fire rated construction (with ¾ hour fire-rated doors) or an approved automatic fire	K 029		

MAY 31 2013  
CONSTRUCTION

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE



TITLE

ADMINISTRATOR

(X6) DATE

5/31/13

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  345419	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01  B. WING _____		(X3) DATE SURVEY COMPLETED  05/15/2013
NAME OF PROVIDER OR SUPPLIER  LEXINGTON HEALTH CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 17 CORNELIA DRIVE LEXINGTON, NC 27292		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 029	Continued From page 1 extinguishing system in accordance with 8.4.1 and/or 19.3.5.4 protects hazardous areas. When the approved automatic fire extinguishing system option is used, the areas are separated from other spaces by smoke resisting partitions and doors. Doors are self-closing and non-rated or field-applied protective plates that do not exceed 48 inches from the bottom of the door are permitted. 19.3.2.1  This STANDARD is not met as evidenced by: Surveyor: 27871 Based on observations and staff interview at approximately 8:30 am onward, the following items were noncompliant, specific findings include: 1. soiled linen door did not close and latch. 2. Infection control door was not self closing.	K 029	K 029  1. Door latch in soiled linen room was repaired on May 16, 2013. Staff will be re-educated concerning necessity to provide work orders for repairs in a timely manner prior to June 29, 2013. Maintenance staff monitors status of doors on a monthly basis as part of the monthly inspections.  2. Self closure device installed to the infection control door on May 17, 2013. The door is now closing and latching as required. Maintenance staff will monitor on a monthly basis as part of the monthly inspection.		
K 038 SS=E	42 CFR 483.70(a) NFPA 101 LIFE SAFETY CODE STANDARD Exit access is arranged so that exits are readily accessible at all times in accordance with section 7.1. 19.2.1  This STANDARD is not met as evidenced by: Surveyor: 27871 Based on observations and staff interview at approximately 8:30 am onward, the following items were noncompliant, specific findings	K 038			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
 CENTERS FOR MEDICARE & MEDICAID SERVICES

 FORM APPROVED  
 OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  345419	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01  B. WING _____		(X3) DATE SURVEY COMPLETED  05/15/2013
NAME OF PROVIDER OR SUPPLIER  LEXINGTON HEALTH CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 17 CORNELIA DRIVE LEXINGTON, NC 27292		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 038	Continued From page 2 include: employee locker room door in kitchen and office beside fire panel room requires two motion of hand to open to exit egress.	K 038	K 038  Door handles and locks on employee locker room and kitchen office were replaced on May 16, 2013 with one motion of hand locks as required.		
K 056 SS=E	42 CFR 483.70(a) NFPA 101 LIFE SAFETY CODE STANDARD  If there is an automatic sprinkler system, it is installed in accordance with NFPA 13, Standard for the Installation of Sprinkler Systems, to provide complete coverage for all portions of the building. The system is properly maintained in accordance with NFPA 25, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems. It is fully supervised. There is a reliable, adequate water supply for the system. Required sprinkler systems are equipped with water flow and tamper switches, which are electrically connected to the building fire alarm system. 19.3.5  This STANDARD is not met as evidenced by: Surveyor: 27871 Based on observations and staff interview at approximately 9:30 am onward, the following items were noncompliant, specific findings include: valve connected to accelerator was not electrical supervised at time of survey.	K 056	K 056  The valve on the sprinkler system connected to accelerator is scheduled for repair and will be completed prior to June 29, 2013.		
K 062 SS=E	42 CFR 483.70(a) NFPA 101 LIFE SAFETY CODE STANDARD  Required automatic sprinkler systems are continuously maintained in reliable operating condition and are inspected and tested	K 062			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
 CENTERS FOR MEDICARE & MEDICAID SERVICES

 FORM APPROVED  
 OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  345419	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01  B. WING _____		(X3) DATE SURVEY COMPLETED  05/15/2013
NAME OF PROVIDER OR SUPPLIER  LEXINGTON HEALTH CARE CENTER		STREET ADDRESS, CITY, STATE, ZIP CODE 17 CORNELIA DRIVE LEXINGTON, NC 27292		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 062	<p>Continued From page 3 periodically. 19.7.6, 4.6.12, NFPA 13, NFPA 25, 9.7.5</p> <p>This STANDARD is not met as evidenced by: Surveyor: 27871 Based on observations and staff interview at approximately 8:30 am onward, the following items were noncompliant, specific findings include; facility could not provide proper documentation at time of survey, that a 3 year full flow test and 5 year obstruction investigation has been performed on sprinkler system.</p> <p>42 CFR 483.70(a)</p>	K 062	<p>K 062</p> <p>Proper Documentation of the 3 year full flow test performed on April 30, 2013 is now on file. The 5 year obstruction investigation has been scheduled and will be performed prior to June 29, 2013.</p>	