

1 10A NCAC 14D .0213 is proposed as a temporary rule as follows:

2  
3 **10A NCAC 14D .0213 OUTSIDE ENTRANCE AND EXITS**

4 (a) An adult day care program offering overnight respite care services shall have at least two exits on all floor  
5 levels. If there are only two, the exit or exit access doors shall be so located and constructed to minimize the  
6 possibility that both may be blocked by any one fire or other emergency condition.

7 (b) At least one entrance and one exit door shall have a minimum width of three feet and another shall be a  
8 minimum width of two feet and eight inches.

9 (c) At least one principal outside entrance and exit for the residents' use shall be at grade level or accessible by ramp  
10 with a one inch rise for each 12 inches of length of the ramp. For the purposes of this Rule, a principal outside  
11 entrance/exit is one that is most often used by residents for vehicular access. If the home has any resident that must  
12 have physical assistance with evacuation, the home shall have two outside entrances and exits at grade level or  
13 accessible by a ramp.

14 (d) All exit door locks shall be easily operable, by a single hand motion, from the inside all times without keys.  
15 Existing deadbolts or turn buttons on the inside of exit doors shall be removed or disabled.

16 (e) All entrances and exits shall be free of all obstructions or impediments to allow for full instant use in case of fire  
17 or other emergency.

18 (f) All steps, porches, stoops and ramps shall be provided with handrails and guardrails.

19 (g) In adult day care programs offering overnight respite care services, with at least one resident who is determined  
20 by a physician or is otherwise known to be disoriented or a wanderer, each exit door for resident use shall be  
21 equipped with a sounding device that is activated when the door is opened. The sound shall be of sufficient volume  
22 that it can be heard by staff. If a central system of remote sounding devices is provided, the control panel for the  
23 system shall be located in the bedroom of the person on call, the office area or in a location accessible only to staff  
24 authorized by the administrator to operate the control panel.

25  
26 *History Note: Authority S.L. 2011-104;*

27 *Eff. January 1, 2012.*