

1 10A NCAC 14D .0212 is proposed for adoption as follows:

2

3 **10A NCAC 14D .0212 CORRIDOR**

4 (a) Corridors shall be lighted with night lights providing one foot-candle power at the floor.

5 (b) Corridors shall be free of all equipment and other obstructions.

6 (c) Corridors shall be equipped with smoke detection that are connected to the building fire alarm system. Heat  
7 detectors are required in attics and basements and connected to the fire alarm system.

8

9 *History Note: Authority S.L. 2011-104;*

10 *Temporary Adoption Eff. January 1, 2012;*

11 *Eff. October 1, 2012.*

12