

1 10A NCAC 13D .3401 is proposed for readoption with substantive changes as follows:

2
3 **SECTION .3400 – MECHANICAL: ELECTRICAL: PLUMBING**

4
5 **10A NCAC 13D .3401 HEATING AND AIR CONDITIONING**

6 (a) A facility shall provide heating and cooling systems complying with the following:

7 (1) The American National Standards Institute and American Society of Heating, Refrigerating, and Air
8 Conditioning Engineers Standard 170: Ventilation of Health Care Facilities, which is incorporated
9 by reference, including all subsequent amendments and editions, and may be ~~purchased for a cost~~
10 ~~of fifty four dollars (\$54.00) online at accessed electronically at~~
11 http://www.techstreet.com/ashrae/lists.ashrae_standards.tmp. This incorporation does not apply to
12 Section 7.1, Table 7-1 Design Temperature for Skilled Nursing Facility. The environmental
13 temperature control systems shall be capable of maintaining temperatures in the facility at 71
14 degrees F. minimum in the heating season and a maximum of 81 degrees F. during the non-heating
15 season; and

16 (2) The National Fire Protection Association 90A: Standard for the Installation of Air-Conditioning
17 and Ventilating Systems, which is incorporated by reference, including all subsequent amendments
18 and editions, and may be ~~purchased at a cost of thirty nine dollars (\$39.00) from the National Fire~~
19 ~~Protection Association online at <http://www.nfpa.org/catalog/> or accessed electronically free of~~
20 ~~charge at <http://www.nfpa.org/aboutthecodes/AboutTheCodes.asp?DocNum=90A>.~~

21 (b) In a facility, the windows in dining, activity and living spaces, and bedrooms shall be openable from the inside.
22 To inhibit patient and resident elopement from any window, the facility may restrict the window opening to a six-inch
23 opening.

24
25 *History Note: Authority G.S. 131E-102; 131E-104;*
26 *Eff. January 1, 1996;*
27 *Amended Eff. July 1, 2014;*
28 *Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. March 22,*
29 *2015-2015;*
30 *Readopted Eff. August 1, 2026.*